

Potable water from Kandaw Gyi Lake, Myanmar

Application: AL-Membran lake water treatment

Date of test: October 2015

Quantity of treated water: up to 2 m³/day

Kandawgyi Lake is one of two major lakes in Myanmar. The lake is artificial; water from Inya Lake is channelled through a series of pipes to this lake. It was created to provide a clean water supply to the city during the British colonial administration. In October 2015 an AL-membrane system was installed to treat up to 2 m³/day to potable water quality.



[Certificate about effluent quality of AL-membrane water treatment](#)

Raw water (Kandaw Gyi Lake):



LABORATORY

Laboratory Technical Consultant: U Saw Christopher Maung
 B.Sc Engg. (Civil), Dip S E (Delft) Lecturer of YIT (Retd), Consultant (Y.C.D.C), LWSE 001.
 Former Member (UNICEF, Water quality monitoring & Surveillance Myanmar)



WTL-RE-001

Issue Date - 01-12-2012
 Effective Date - 01-12-2012
 Issue No - 1.0/Page 1 of 2

W1015 098

WATER QUALITY TEST RESULTS FORM

Client Mingalar Myanmar
 Nature of Water Pond Water (Raw)
 Location Kandawgyi
 Date and Time of collection 7.10.2015
 Date and Time of arrival at Laboratory 7.10.2015
 Date and Time of commencing examination 8.10.2015
 Date and Time of completing 10.10.2015

Results of Water Analysis

WHO Drinking Water Guideline (Geneva - 1993)

pH	7.4		6.5 - 8.5
Colour (True)	75	TCU	15 TCU
Turbidity	103	NTU	5 NTU
Conductivity		micro S/cm	
Total Hardness	46	mg/l as CaCO ₃	500 mg/l as CaCO ₃
Calcium Hardness		mg/l as CaCO ₃	
Magnesium Hardness		mg/l as CaCO ₃	
Total Alkalinity		mg/l as CaCO ₃	
Phenolphthalein Alkalinity		mg/l as CaCO ₃	
Carbonate (CaCO ₃)		mg/l as CaCO ₃	
Bicarbonate (HCO ₃)		mg/l as CaCO ₃	
Iron	0.98	mg/l	0.3 mg/l
Chloride (as CL)	12	mg/l	250 mg/l
Sodium chloride (as NaCL)		mg/l	
Sulphate (as SO ₄)	Nil	mg/l	200 mg/l
Total Solids	180	mg/l	1500 mg/l
Suspended Solids		mg/l	
Dissolved Solids	64	mg/l	1000 mg/l
Manganese	Nil	mg/l	0.05 mg/l
Phosphate		mg/l	
Phenolphthalein Acidity		mg/l	
Methyl Orange Acidity		mg/l	
Salinity		ppt	

Remark: This certificate is issued only for the receipt of the test sample.

Tested by

Signature: Zaw Hein Oo

Name: B.Sc (Chemistry)
Chemist

Approved by

Signature: Soe Thin

Name: a.B (Civil) 1980

Technical Officer,
ISO TECH Laboratory

(a division of WEG Co., Ltd.) ISO TECH Laboratory

No.18, Lanthit Road, Nanthargone Quarter, Insein Township, Yangon, Myanmar

Ph: 01-640955, 09-73225175, 09-73242162, Fax: 01-644506, E-mail: isotechlaboratory@gmail.com, Website: weg-myanmar.com



LABORATORY

Laboratory Technical Consultant: U Saw Christopher Maung
 B.Sc Engg. (Civil), Dip S E (Delft) Lecturer of YIT (Retd), Consultant (Y.C.D.C), LWSE 001
 Former Member (UNICEF, Water quality monitoring & Surveillance Myanmar)



WTL-RE-001
 Issue Date - 01-12-2012
 Effective Date - 01-12-2012
 Issue No - 1.0/Page 2 of 2

W1015 098

WATER QUALITY TEST RESULTS FORM

Client Mingalar Myanmar
 Nature of Water Pond Water (Raw)
 Location Kandawgyi
 Date and Time of collection 7.10.2015
 Date and Time of arrival at Laboratory 7.10.2015
 Date and Time of commencing examination 8.10.2015
 Date and Time of completing 10.10.2015

Results of Water Analysis

WHO Drinking Water Guideline (Geneva - 1993)

Temperature (°C)	°C	
Fluoride (F)	mg/l	1.5 mg/l
Lead (as Pb)	mg/l	0.01 mg/l
Arsenic (As)	mg/l	0.01 mg/l
Nitrate (N.NO ₃)	1.4 mg/l	50 mg/l
Chlorine (Residual)	mg/l	
Ammonia (NH ₃)	mg/l	
Ammonium (NH ₄)	mg/l	
Dissolved Oxygen (DO)	mg/l	
Chemical Oxygen Demand (COD)	mg/l	
Biochemical Oxygen Demand (BOD) (5 days at 20 °C)	mg/l	
Cyanide (CN)	mg/l	0.07 mg/l
Zinc (Zn)	mg/l	3 mg/l
Copper (Cu)	mg/l	2 mg/l
Silica (Si)	mg/l	

Remark: This certificate is issued only for the receipt of the test sample.

Tested by

Signature: *Heira*
 Name: **Zaw Hein Oo**
B.Sc (Chemistry)
Chemist
ISO TECH Laboratory

Approved by

Signature: *Saw Chit*
 Name: **Saw Chit**
B.E (Civil) 1980
Technical Officer
ISO TECH Laboratory

(a division of WEG Co.,Ltd.)

No.18, Lanthit Road, Nanthargone Quarter, Insein Township, Yangon, Myanmar.

Ph: 01-640955, 09-73225175, 09-73242162, Fax: 01-644506, E-mail: isotechlaboratory@gmail.com, Website: weg-myanmar.com

Treated water after installation of AL-Membran



LABORATORY

Laboratory Technical Consultant: U Saw Christopher Maung
 B.Sc Engg. (Civil), Dip S.E (Delft) Lecturer of YIT (Retd), Consultant (Y.C.D.C), LWSE 001.
 Former Member (UNICEF, Water quality monitoring & Surveillance Myanmar)

WTL-RE-001

Issue Date - 01-12-2012

Effective Date - 01-12-2012

Issue No - 1.0/Page 1 of 2

W1015 097

WATER QUALITY TEST RESULTS FORM

Client Mingalar Myanmar
 Nature of Water Pond Water (Treated)
 Location Kandawgyi
 Date and Time of collection 7.10.2015
 Date and Time of arrival at Laboratory 7.10.2015
 Date and Time of commencing examination 8.10.2015
 Date and Time of completing 10.10.2015

Results of Water Analysis

WHO Drinking Water Guideline (Geneva - 1993)

pH	6.9		6.5 - 8.5
Colour (True)	Nil	TCU	15 TCU
Turbidity	1	NTU	5 NTU
Conductivity		micro S/cm	
Total Hardness	44	mg/l as CaCO ₃	500 mg/l as CaCO ₃
Calcium Hardness		mg/l as CaCO ₃	
Magnesium Hardness		mg/l as CaCO ₃	
Total Alkalinity		mg/l as CaCO ₃	
Phenolphthalein Alkalinity		mg/l as CaCO ₃	
Carbonate (CaCO ₃)		mg/l as CaCO ₃	
Bicarbonate (HCO ₃)		mg/l as CaCO ₃	
Iron	0.03	mg/l	0.3 mg/l
Chloride (as CL)	8	mg/l	250 mg/l
Sodium chloride (as NaCL)		mg/l	
Sulphate (as SO ₄)	Nil	mg/l	200 mg/l
Total Solids	63	mg/l	1500 mg/l
Suspended Solids		mg/l	
Dissolved Solids	62	mg/l	1000 mg/l
Manganese	Nil	mg/l	0.05 mg/l
Phosphate		mg/l	
Phenolphthalein Acidity		mg/l	
Methyl Orange Acidity		mg/l	
Salinity		ppt	

Remark: This certificate is issued only for the receipt of the test sample.

Tested by

Signature: Zaw Hein Oo

Name: B.Sc (Chemistry)

Chemist

ISO-TECH Laboratory

Approved by

Signature: Soe Thi

Name: B.E (Civil) 1980

Technical Officer

ISO-TECH Laboratory

(a division of WEG Co.,Ltd.)

No.18, Lanthit Road, Nanthargone Quarter, Insein Township, Yangon, Myanmar.

Ph: 01-640955, 09-73225175, 09-73242162, Fax: 01-644506, E-mail: isotechlaboratory@gmail.com, Website: weg-myanmar.com



LABORATORY

Laboratory Technical Consultant: U Saw Christopher Maung
 B.Sc Engg. (Civil), Dip S.E (Delft) Lecturer of YIT (Retd), Consultant (Y.C.D.C), LWSE 001.
 Former Member (UNICEF, Water quality monitoring & Surveillance Myanmar)



WTL-RE-001
 Issue Date - 01-12-2012
 Effective Date - 01-12-2012
 Issue No - 1.0/Page 2 of 2

W1015 097

WATER QUALITY TEST RESULTS FORM

Client Mingalar Myanmar
 Nature of Water Pond Water (Treated)
 Location Kandawgyi
 Date and Time of collection 7.10.2015
 Date and Time of arrival at Laboratory 7.10.2015
 Date and Time of commencing examination 8.10.2015
 Date and Time of completing 10.10.2015

Results of Water Analysis

WHO Drinking Water Guideline (Geneva - 1993)

Parameter	Result	Unit	Guideline
Temperature (°C)		°C	
Fluoride (F)	0.3	mg/l	1.5 mg/l
Lead (as Pb)	Nil	mg/l	0.01 mg/l
Arsenic (As)	Nil	mg/l	0.01 mg/l
Nitrate (N.NO ₃)	Nil	mg/l	50 mg/l
Chlorine (Residual)		mg/l	
Ammonia (NH ₃)		mg/l	
Ammonium (NH ₄)		mg/l	
Dissolved Oxygen (DO)		mg/l	
Chemical Oxygen Demand (COD)		mg/l	
Biochemical Oxygen Demand (BOD) (5 days at 20 °C)		mg/l	
Cyanide (CN)	Nil	mg/l	0.07 mg/l
Zinc (Zn)	Nil	mg/l	3 mg/l
Copper (Cu)	Nil	mg/l	2 mg/l
Silica (Si)		mg/l	

Remark: This certificate is issued only for the receipt of the test sample.

Tested by

Signature: *Hein Oo*
 Name: **Zaw Hein Oo**
B.Sc (Chemistry)
Chemist
ISO TECH Laboratory

Approved by

Signature: *Soe Thin*
 Name: **Soe Thin**
6.8 (Civil) 1980
Technical Officer
ISO TECH Laboratory

(a division of WEG Co.,Ltd.)

No.18, Lanthit Road, Nanthargone Quarter, Insein Township, Yangon, Myanmar.
 Ph: 01-640955, 09-73225175, 09-73242162, Fax: 01-644506, E-mail: isotechlaboratory@gmail.com, Website: weg-myanmar.com